




**BUREAU
VERITAS**

ATTESTATION of conformity with European Directives

BV LCIE CHINA Number N°2466AS06GYB55449

Product Transfer Switching Equipment (Class PC)

Reference G2R-63

Trademark 

Issued to ZHEJIANG GEYA ELECTRICAL CO., LTD

Address WENZHOU BRIDGE INDUSTRIAL ZONE, BEIBAIXIANG TOWN,
YUEQING, ZHEJIANG, 325603 - CHINA

Manufacturer ZHEJIANG GEYA ELECTRICAL CO., LTD

Address WENZHOU BRIDGE INDUSTRIAL ZONE, BEIBAIXIANG TOWN,
YUEQING, ZHEJIANG, 325603 - CHINA

Technical characteristics

Poles: 1P+N

Ue: 220V~ Ui:690V, Uimp:8kV; 50/60Hz

Ie: 16A,20A, 32A,40A,50A,63A

Utilization Category: AC-31B, Icw: 5kA/0,03s

Class A

The submitted sample of the above equipment has been tested according to following European Directive and following standards:

LVD Directive 2014/35/EU

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
EN IEC 60947-6-1:2023	24119Y90007	2024-06-11

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product.

Shanghai (P.R. China), June 18th, 2024.

Product Line Manager

Charlie CHEN



This document shall not be reproduced, except in full, without the written approval of BV LCIE China. Information given in this document is related to the tested specimen of the described electrical sample.